

**Section 1207.4.1 Electrical disconnects** is adopted without amendment.

**1207.4.1 Electrical disconnects.** Where the ESS disconnecting means is not within sight of the main electrical service disconnecting means, placards or directories shall be installed at the location of the main electrical service disconnecting means indicating the location of stationary storage battery system disconnecting means in accordance with *the California Electrical Code*. ~~The ESS disconnecting means shall be within 36-inches of the main electrical service disconnecting means. The ESS disconnecting means shall be labeled “ESS Emergency Stop”.~~

**Exception:** Electrical disconnects for lead-acid and nickel-cadmium battery systems at facilities under the exclusive control of communications utilities and operating at less than 50 VAC and 60 VDC shall be permitted to have electrical disconnects signage in accordance with NFPA 76.

**Section 1207.11.5.1 ESS Electrical disconnect in Group R-3 and R-4 occupancies** is hereby added as follows:

**1207.11.5.1 ESS Electrical disconnect in Group R-3 and R-4 occupancies.** The ESS disconnecting means shall be provided within 36-inches of the main electrical service disconnecting means. The ESS disconnecting means shall be labeled “ESS Emergency Stop”.

**Chapter 20  
Aviation Facilities**

**Chapter 20 Aviation Facilities** is adopted in its entirety without amendment.

**Chapter 21  
Dry Cleaning**

**Chapter 21 Dry Cleaning** is adopted in its entirety without amendment.

**Chapter 22  
Combustible Dust-Producing Operations**

**Chapter 22 Combustible Dust-Producing Operations** is adopted in its entirety without amendment.

**Chapter 23  
Motor Fuel-Dispensing Facilities and Repair Garages**

**Chapter 23 Motor Fuel-Dispensing Facilities and Repair Garages** is adopted in its entirety without amendment.

**Chapter 24**